



KLIMAS

VDS 4001 : 2021-01 – Torque-controlled expansion anchors
LE-ZNA4, LE-A4, LE-DA4

We hereby confirm that the following anchors:

LE-ZNA4, LE-A4, LE-DA4 in the sizes : **M8, M10, M12, M16**



are in full compliance with guidelines:

VdS-CEA 4001:2021-01 - *Guidelines for sprinklers systems. Planning and installation*

for applications of water extinguishing systems on concrete elements according to provisions mentioned in the point 15.2.4.

Torque-controlled expansion anchors are approved with **European Technical Assessment ETA-20/0641** issued on the basis of the European Assessment Document - **EAD 330232-01-0601**, with intended use for cracked and non-cracked concrete substrate.

Klimas Sp. z o.o.


ul. W. Witosa 135/137

Kuźnica Kiedrzyńska | 42-233 Mykanów


Wiktor Paradny
Global Product Manager

Klimas Sp. z o.o.
ul. Wincentego Witosa 135/137
Kuźnica Kiedrzyńska
42-233 Mykanów
tel. +48 34 377 71 00
fax +48 34 328 01 73

Kierownik działu technicznego


Adam Szczepanowski
- 415 -

Adam Szczepanowski
Manager of Technical Department

office@wkret-met.com
www.wkret-met.com
NIP 573-24-08-654
KRS 0000168164
Kapitał Zakładowy: 200 000,00 PLN