



**VDS 4001 : 2021-01 – Concrete screws WDB-LS, WDB-LP, WDB-LG,
WDB-GW – multiple non-structural systems**

We hereby confirm that the following concrete screws :

WDB-LS in the sizes : **6 (7,5), 8 (9,9)**

WDB -LP/LG/GW in the size : **6 (7,5)**



are in full compliance with guidelines:

VdS-CEA 4001:2021-01 - *Guidelines for sprinklers systems. Planning and installation*

for applications of water extinguishing systems on concrete elements according to provisions mentioned in the point 15.2.4.

Concrete screws are approved with **European Technical Assessment ETA-20/0769** issued on the basis of the European Assessment Document - **EAD 330747-00-0601**, with intended use for cracked and non-cracked concrete substrate.

Klimas Sp. z o.o.

ul. W. Witosa 135/137

Kuźnica Kiedrzyńska | 42-233 Mykanów

Wiktor Paradny
Global Product Manager

Klimas Sp. z o.o.
ul. Wincentego Witosa 135/137
Kuźnica Kiedrzyńska
42-233 Mykanów
tel. +48 34 377 71 00
fax +48 34 328 01 73

Kierownik działu technicznego

Adam Szczepanowski
- 415 -

Adam Szczepanowski
Manager of Technical Department

office@wkret-met.com
www.wkret-met.com
NIP 573-24-08-654
KRS 0000168164
Kapitał Zakładowy: 200 000,00 PLN